



# PELAN TAPAK


Petunjuk:

Cadangan

-  Kabel B/Tanah KVT 240mmp x 3 teras xlpe alum (11kV)
-  Kabel B/Tanah KVT 7X500mmp x 1 teras PVC/PVC Cu (1kV)
-  Sambungan terus
-  Corrugated 150MMP(70m)
-  Potong dan tinggal


Sediada

-  Kabel B/Tanah KVT 240mmp x 3 teras xlpe alum (11kV)
-  Meter Kiosk



4.702520, 101.098757

JALAN SERAMIK CHEPOR 11/6  
4.702389, 101.098486



Kawasan : Daerah  
No. Fail : D-TGR-C24-1948

PERMOHONAN TAMBAHAN BEKALAN ELEKTRIK BAGI MENDIRIKAN BANGUNAN (KM11) BAGI CADANGAN TAMBAHAN 'COMPACT SUBSTATION' KEPADA KILANG YANG SEDIADA DI ATAS LOT 197241, JALAN CHEPOR 11/5, KAWASAN PERUSAHAAN SERAMIK CHEPOR, 31200 CHEMOR, MUKIM HULU KINTA, DAERAH KINTA, PERAK UNTUK TETUAN GLOBAL OUTDOORS SDN. BHD. (NO. AKAUN - 210232554503)

ALL RIGHTS RESERVED  
LUKISAN INI TIDAK BOLEH DIUBAHSUAI  
TANPA KEBENARAN DARI JURUTERA  
TENAGA NASIONAL BERHAD

Pindaan	Dilukis : ALIAS	Diluluskan : RAJA HANI
	Disemak : SHUHALMI	Tarikh : 15/08/2024
	No. Lukisan :	C/POH/PTAPAK/TGR 1948