



Petunjuk: (Sediada)  
 ● Tiang Konkrit 9.0m

Petunjuk: (Cadangan)  
 - - - Kabel B/Tanah VR 185mmp x 4 teras xlpe alum (1kV)  
 - - - Sesalur Atas VR ABC 3x16+25mmp  
 ● Tiang Konkrit 9.0m  
 ▨ HDD PN10



Kawasan BESAUT Daerah SUNGKAI  
 No. Fail : 11001023055

### FGV AGRI SERVICES

ALL RIGHTS RESERVED  
 LUKISAN INI TIDAK BOLEH DIUBAHSUAI  
 TANPA KEBENARAN DARI JURUTERA  
 TENAGA NASIONAL BERHAD

Pindaan	Dilukis : SHAKIR	Diluluskan : EN IKRAM
	Disemak : ZAINI	Tarikh : 14/05/26
	No. Lukisan :	