



NOTES :

- I) D.I OR STEEL PIPE WILL BE USED AT ROAD AND CULVERT CROSSING.
- II) AIR VALVES, SCOUR VALVES, SLUICE VALVES AND HYDRANT WILL BE FIXED ON SITE WHERE NECESSARY.
- III) PIPELINE ALIGNMENT WILL BE FIXED ON SITE WHERE NECESSARY.
- IV) VALVE CHAMBERS TO BE APPROVED BY SYARIKAT AIR TERENGGANU (SATU).
- V) THIS DRAWING IS FOR REFERENCE ONLY, SUBJECT TO CHANGES WHEN LICENSED SURVEYOR APPOINTMENT

All rights reserved. These drawings, plans and specifications and copyright therein are the property of Syarikat Air Terengganu (SATU) and must not be used, reproduced or copied wholly or in part without the written permission of Syarikat Air Terengganu (SATU).

AUTHORITIES APPROVAL :

PROJECT TITLE :

MEMBEKAL, MEMASANG DAN MENGUJI PAIP AIR BERSAIZ 155MM DIA. MULTI-LAYER UPVC PN12 BELLMOUTH DAN PAIP MS BERSAIZ 150MM DIA. SERTA PENGALIHAN TAPPING SEDIADA DAN LAIN-LAIN KERJA YANG BERKAITAN DI KG. GERDONG, DAERAH HULU TERENGGANU, TERENGGANU DARUL IMAN.

PIHAK BERKUASA PENGALIHAN AIR :

SYARIKAT AIR TERENGGANU SENDIRIAN BERHAD
(453286-D)

JALAN SULTAN ISMAIL
20200 KUALA TERENGGANU
TERENGGANU
TEL : 09-6214111 / 09-6201111 FAX : 09-6201104

REVISION :	DESCRIPTION	DATE	SIGN

DRAWING TITLE :

- OVERALL LAYOUT PLAN

DESIGNED BY	SATU	DATE	SEP 2023
DESIGN CHK'D BY	SATU	DATE	SEP 2023
DRAWN BY	SATU	DATE	SEP 2023
DWG CHK'D BY	SATU	DATE	SEP 2023
SCALE	1 : 5000		
JOB NO	DRAWING NO	ISSUE	
JBA/SATU/T/02/2025	JBA/SATU/T/02/2025 - OLP	0	