



PE ULU KUANG 1



Cadangan Merentang 1 x 50m kabel
11kV XLPE 150mmp 3C dari PE Kg Ulu
Kuang 1 ke tiang no 1



Merentang 1 x sesalur ABC 3x150mmp, 3C 11kV
sejauh 1100m dari PE Kg Ulu Kuang 1 ke PAT Kg
Ulu Kuang 2



PAT ULU KUANG 2

Merentang 1 x 50m kabel 11kV XLPE
150mmp 3C dari PE Kg Ulu Kuang 2 ke
tiang depan PE