



Das merenthang LIDC KVT di antara
 SBU Industri Pakai ke PE Elektroserve
 Sejalan 42 meter
 Mula: 4°35'51.6" N 103°26'36.4" E
 Tamat: 4°35'52.2" N 103°26'36.9" E

Produk KVT 2x150mmp di tanah(20 meter)
 Mula: 4°35'51.6" N 103°26'36.4" E
 Tamat: 4°35'51.7" N 103°26'36.7" E

2 NOS XLPE pipe 150mmp MIL&Pave
 CORING EAST (E.M)
 Mula: 4°35'51.7" N 103°26'36.7" E
 Tamat: 4°35'52.1" N 103°26'37.2" E

Produk KVT 150mmp di tanah(10 meter)
 Mula: 4°35'51.7" N 103°26'36.7" E
 Tamat: 4°35'51.9" N 103°26'36.9" E

Produk KVT 150mmp di tanah(10 meter)
 Mula: 4°35'51.7" N 103°26'36.7" E
 Tamat: 4°35'52.2" N 103°26'36.9" E

CAD CSU
 MENCANTARI

DPELO ELEKTRO SERVE

LEGEND :

— CAD KVT 150MMP XLPE 3C 11KV

--- SEDIADA KVT 150MMP XLPE 3C 11KV

DR. SITI HIN AB. LATIF
 Ketua Aseel / Juruera Kanan
 Civil Planning 11KV & LV - Tenaga
 Aseel Planning & Performance Zone
 Kalamian / Terengganu
 E-mail: dr.siti@tenaga.com.my



NAME	DATE
DRAWN BY Alhna	10.05.24
CHECKED BY	10.05.24
APPROVED BY Mohd Yusri	10.05.24

TITLE :
 BE KE 2 UNIT BENGKEL FABRIKASI
 SEPARA TERTUTUP, 1 UNIT BENGKEL
 BLASTING& PAINTING, 1 UNIT
 PEJABAT SETINGKAT DI LOT 9718
 (PM 2441) LOT 9717 (PM 2442) LOT
 9720 (PM 2443) TMN INDUSTRI PAKA
 D-DUN-C23-1366

SCALE : n.t.s.

DATE : 10.05.24 DRAWING No. :
 DUN 1366-24