

PELAN TAPAK D-TEL-S26-5273

Distribution PE LVDB-FP



PETUNJUK

-  CAD. PENCAWANG SEMI INDOOR 10mX7m
-  CAD. JOINT STRAIGHT TRUE 3C XLPE 150MMP
-  KABEL SEDIADA XLPE 3C 150MMP 11KV
-  CAD. RENTANG 1 KABEL XLPE 3C 150MMP 11KV
-  CAD. PAIP HDD 150MM SEJAUH 60 METER



KUALANGAN PERUM LAMPUNG TUNJAY
No. FILE: D-TEL-S26-5273

KELOMPOK PERUM
DILAKSI: MEND PERUM
DISORONG: MEND PERUM
DIREKTOR: EN MEND PERUM
DIBINA: DELOLAW

MSVT MEMUJUKAN PENCAWANG BARU DI KAWASAN LORONG MAD NAYAN BAGI MENGATASI MASALAH LOW VOLTAGE.

No. LUKSMAK: MSVT 5273