



- Petunjuk: (Sedia ada)**
-  Peti Pembekal 1600A
  -  Sesalur Atas VR ABC 3x95+70+16mmp
  -  Tiang konkrit 9.0m
- Petunjuk: (Cadangan)**
-  Kabel B/Tanah VR 185mmp x 4 teras XLPE AL (1kV)
  -  Sesalur Atas VR ABC 3x185+120+16mmp
  -  Sesalur Atas VR ABC 3x95+70+16mmp
  -  Sesalur KakiLima PVC 19/064 (35mmp)
  -  Corrugated 100mmp Open Cut Tar (85m)
  -  Black Box 160A
  -  Stay
  -  Tiang konkrit 9.0m

 <b>TENAGA NASIONAL</b> BERHAD				
Kawasan	ULU KINTA	Daerah		
No. Fail :	11000872607			
<b>KINTA KEMAS SDN BHD</b>				
Pindaan	Ditulis :	SHAKIR	Diluluskan :	FAHMI
	Disemak :	SHAHRUL	Tarikh :	14.11.24
	No. Lukisan :			