







NOTA KERJA-KERJA DI PENCAWANG :

- ITC TX 500KVA KE 1000KVA
- CAD BINA BARU F/PILLAR 1600A
- CAD LAY CABLE 7X500MMP CU DARI TX KE FP1600
- CAD LAY CABLE 300MMP SINGLE CORE X 2 DARI FP1600 KE LVDB 800A

KETERANGAN

-  TIANG SPUN KONKRIT 9M BARU
-  CAD. UMBANG SUDUT BARU
-  CAD SUB F/PILLAR 800A
-  CAD PIPE HDPE PN10 150MMP
-  CAD UG CABLE 4C 300MMP XLPE (OPEN CUT)
-  CAD UG CABLE 4C 185MMP XLPE
-  CAD. BARU TALIAN ABC 3X95+70+16MMP
-  CAD F/PILLAR 1600



NEGERI : PERAK SUBZONE : TELUK INTAN
No FAIL :SN : 110000917347

KELUARAN PERTAMA
Dilukis oleh: FAIZ
Disemak oleh: FAMI
Diluluskan oleh: EN RATHA
Tarikh: 07/07/2025

PERMOHONAN BEKALAN UNTUK TETUAN MAINLAND SEASONS SDN BHD DI PLOT 1 - PLOT 3, SEBAHAGIAN LOT 25 PEKAN SIMPANG EMPAT, HILIR PERAK, 36400 HUTAN MELINTANG, PERAK.