







Penunjuk:

-  CADANGAN TALIAN ABC 3X185+120+16MMP
-  SEDIADA TALIAN ABC 3X185+120+16MMP
-  CADANGAN TALIAN ABC 3X95+70+16MMP
-  SEDIADA TIANG 9.0M 2KN
-  CADANGAN TUKAR TIANG 9.0M 2KN (ASAL 7.5M)
-  CADANGAN TIANG BARU 9.0M 2KN

- (A) — (B) SEDIADA TIANG SPUN 4 BATANG (KABEL TALIAN ATAS SEJAUH 100 METER)
- (B) — (C) CADANGAN TUKAR TIANG SPUN 3 BATANG DAN TAMBAH TIANG BARU 1 BATANG (KABEL TALIAN ATAS SEJAUH 90 METER)



TENAGA NASIONAL

NEGERI: TERENGGANU DAERAH: KUALA TERENGGANU

TARIKH	22/04/2025
NEL LUKISAN	KTR 4942-C
DILUKIS OLEH	Tc. ANUAR YUSOF
DISEMAK OLEH	SHAKRI MOHD
DILULUSKAN OLEH	Ir. Ts. NUR HALAWATI MOHAMAD

TAJUK: KTR 4942
 PERMOHONAN BEKALAN 3 FASA 60AMP
 KE 1 UNIT RUMAH PT 1114, JLN BKT
 LOSONG, LOSONG PANGLIMA
 PERANG, 21000 KUALA
 TERENGGANU, TERENGGANU (NURUL
 SYAHIRAH BINTI YUSOF)