



Wisma TNB, Jalan Lahat

MEWUJUDKAN INTERCONNECTION ANTARA PMU TEMOH 132/33/11KV DENGAN SSU UTAR 33KV

Dilukis: AHMAD HADRI B SHAFARUDDIN	Tarikh: 18.2.2025
Disemak: ZULKHAIRI	No.Projek: D-PZA-S19-1736
Diluluskan: RAJA NURULHANI	Skala: NOT TO SCALE
Ruj: \\tnb\will\PZA1736\5	

PETUNJUK :

	Cadangan merentang 1 liter kabel ABC 33kv 150 mmp XLPE Al. (16 km)
	Cadangan kabel bawah tanah triplex 33kv 150 mmp XLPE Al. (1220 m)
	Cadangan kabel bawah tanah 33kv 630 mmp XLPE Al. (1000 m)
	Cadangan HDD

PMU TEMOH  
132kv, 2X90MVA

HDD 8  
60 m